

**GOVERNMENT OF TRIPURA
O/O THE ASSISTANT ENGINEER, PWD(R&B)
TELIAMURA SUB-DIVISION NO-I
TELIAMURA, KHOWAI, TRIPURA.**

NO.F.5(12)/AE/PWD/TLM-I/433-34

Dated:- Teliamura, 27th Aug', 2026

✓ To,

The Vice-Principal

Kabi Nazrul Vidyabhaban H.S. School
Joynagar, Teliamura, Khowai, Tripura.

Subject:- Issue of building safety certificate against Kabi Nazrul Vidyabhaban H.S. School.


Reference:- Your letter No.F.1(6)/HM-KNV/TLM/2023/733, dt. 21/08/2026.

Sir,

Kindly refer to the above, this is to certified that on visual observation of the building, it is found that the building are seems to safe. During inspection it is found that roof treatment may be done for betterment of drain out of rain water. This certificate relates to the present condition of walling, door, windows and GCI sheet roofing etc. However the foundation condition of the building could not be assessed.

This is issued in connection with the proposal of the School as mentioned in the above letter.

Yours faithfully,



**(Er. B. Chaudhury)
Assistant Engineer, PWD(R&B)
Teliamura Sub-Division No-I
Teliamura, Khowai, Tripura**

Copy to:-

1. The Executive Engineer, PWD, Teliamura Division, Teliamura for favour of his kind information please.

/

**(Er. B. Chaudhury)
Assistant Engineer, PWD(R&B)
Teliamura Sub-Division No-I**

